



## Drinking Water Results Report

Order ID: 9054773

Suburban Property Inspections  
4600 Kutztown Road  
Temple, PA 19560

Attn: Jonathan D. Stump

Project: Philadelphia OIC  
1231 N. Broad St, 4th Floor  
Philadelphia, PA 19122

PWSID:

Sample Number: 9054773-01

Site: A

Sample ID: 2nd, Ladies, Sink 3

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:41	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:41	MAW

Sample Number: 9054773-02

Site: B

Sample ID: 2nd, Ladies, Sink 2

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:35	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 0:35	MAW

Sample Number: 9054773-03

Site: C

Sample ID: 2nd, Ladies, Sink 1

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:41	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 0:41	MAW

Sample Number: 9054773-04

Site: D

Sample ID: 2nd, Staff Bathroom

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

### Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:41	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:44	MAW

Sample Number: 9054773-05

Site: E

Sample ID: 2nd Fl, Mens Room, Sink # 2

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Report Generated On: 06/05/2019 12:46 pm  
STL\_DW\_Results Revision #1.7

9054773  
Effective: 07/09/2014



# SUBURBAN TESTING LABS

Sample Number: 9054773-05 Site: E Sample ID: 2nd FI, Mens Room, Sink # 2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:43	MAW
Lead, Standing	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:46	MAW

Sample Number: 9054773-06 Site: F Sample ID: 2nd, Mens Sink 1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:45	MAW
Lead, Standing	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:48	MAW

Sample Number: 9054773-07 Site: G Sample ID: 3rd FI, Hallway Water Fountain  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:47	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:50	MAW

Sample Number: 9054773-08 Site: H Sample ID: 3rd FI, Ladiesroom, Sink 1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:49	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:52	MAW

Sample Number: 9054773-09 Site: I Sample ID: 3rd, Ladies, Sink 2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:54	MAW
Lead, Standing	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:54	MAW

Sample Number: 9054773-10 Site: J Sample ID: 3rd FI, Mens Room Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-10 Site: J Sample ID: 3rd Fl, Mens Room Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	0.014	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 1:22	MAW
Lead, Standing	0.071	mg/L	EPA 200.8	0.015	Fail	0.005	05/30/19	RPV	06/05/19 1:22	MAW

Sample Number: 9054773-11 Site: K Sample ID: 3rd, Mens Sink 3  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:58	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:56	MAW

Sample Number: 9054773-12 Site: L Sample ID: 5th, Staff Bathroom  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:00	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:02	MAW

Sample Number: 9054773-13 Site: M Sample ID: 1st, Fl, Sink  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:02	MAW
Lead, Standing	0.002 T1	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:04	MAW

Sample Number: 9054773-14 Site: N Sample ID: 3rd, Kitchen Sink  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:04	MAW
Lead, Standing	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:06	MAW

Sample Number: 9054773-15 Site: O Sample ID: 4th Water Fountain Lunch Room  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-15 Site: O Sample ID: 4th Water Fountain Lunch Room  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:06	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:08	MAW

Sample Number: 9054773-16 Site: P Sample ID: 5th, Small Mens Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:08	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:10	MAW

Sample Number: 9054773-17 Site: Q Sample ID: 4th FI, Mens Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:10	MAW
Lead, Standing	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:12	MAW

Sample Number: 9054773-18 Site: R Sample ID: 5th, Small Mens Sink #2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:12	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:14	MAW

Sample Number: 9054773-19 Site: S Sample ID: 5th FI, Ladies Room Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/05/19 0:18	MAW
Lead, Standing	0.004	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:16	MAW

Sample Number: 9054773-20 Site: T Sample ID: 4th FI, Lounge, Sink  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-20

Site: T

Sample ID: 4th Fl, Lounge, Sink

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:43	MAW
Lead, Standing	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:18	MAW

Sample Number: 9054773-21

Site: U

Sample ID: 5th, Large Mens Sink #2

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:49	MAW
Lead, Standing	0.008	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 21:20	MAW

Sample Number: 9054773-22

Site: V

Sample ID: 5th Fl, Water Fountain Near Sky Room

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:33	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:40	MAW

Sample Number: 9054773-23

Site: W

Sample ID: 5th, Starbucks Sink #2

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:35	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:42	MAW

Sample Number: 9054773-24

Site: X

Sample ID: 5th FL, Starbucks Sink #1

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:37	MAW
Lead, Standing	0.005	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:48	MAW

Sample Number: 9054773-25

Site: Y

Sample ID: 5th Fl, Ladies Room, Sink #2

Collector: Client

Collect Date: 05/04/2019 7:00 am

Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm

9054773

STL\_DW\_Results Revision #1.7

Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-25 Site: Y Sample ID: 5th Fl, Ladies Room, Sink #2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:39	MAW
Lead, Standing	0.003	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:49	MAW

Sample Number: 9054773-26 Site: Z Sample ID: 5th, Large Mens Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:41	MAW
Lead, Standing	0.003	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:51	MAW

Sample Number: 9054773-27 Site: AA Sample ID: 4th FL, Mens Sink #2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:47	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:53	MAW

Sample Number: 9054773-28 Site: AB Sample ID: 4th FL, Ladies Room Sink #2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:49	MAW
Lead, Standing	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:55	MAW

Sample Number: 9054773-29 Site: AC Sample ID: 4th FL, HTI Ladies, Sink #2  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:51	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:57	MAW

Sample Number: 9054773-30 Site: AD Sample ID: 4th FL, Ladies Room Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-30 Site: AD Sample ID: 4th FL, Ladies Room Sink #1  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:56	MAW
Lead, Standing	0.007	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:01	MAW

Sample Number: 9054773-31 Site: AE Sample ID: 4th FL, HTI, Water Fountain  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 22:58	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:04	MAW

Sample Number: 9054773-32 Site: AF Sample ID: 3rd FI, Mens Room, Sink #2  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:00	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:07	MAW

Sample Number: 9054773-33 Site: AG Sample ID: 4th, Ladies Sink #3  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:02	MAW
Lead, Standing	0.004 T1	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:15	MAW

Sample Number: 9054773-34 Site: AH Sample ID: 4th FL, Mens Room, HTI Sink #1  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:04	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:17	MAW

Sample Number: 9054773-35 Site: AI Sample ID: 4th FI, Mens Room, Sink #3  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-35 Site: AI Sample ID: 4th Fl, Mens Room, Sink #3  
Collector: Client Collect Date: 05/04/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:10	MAW
Lead, Standing	0.003	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:19	MAW

Sample Number: 9054773-36 Site: AJ Sample ID: 2nd FL, Water Fountain  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:12	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:21	MAW

Sample Number: 9054773-37 Site: AK Sample ID: 4th Fl, HTI, Mens Room, Sink #2  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:14	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:23	MAW

Sample Number: 9054773-38 Site: AL Sample ID: 4th, HTI, Ladies Room, Sink #3  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:16	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 20:25	MAW

Sample Number: 9054773-39 Site: AM Sample ID: 3rd Fl, Slop Sink  
Collector: Client Collect Date: 05/14/2019 7:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

## Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RJS	06/04/19 23:18	MAW
Lead, Standing	0.006	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	RPV	05/30/19 19:59	MAW

Sample Number: 9054773-40 Site: AN Sample ID: 4th FL, HTI Ladies, Sink #1  
Collector: Client Collect Date: 05/11/2019 7:00 am Sample Type: Grab

Report Generated On: 06/05/2019 12:46 pm 9054773  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS

Sample Number: 9054773-40

Site: AN

Sample ID: 4th FL, HTI Ladies, Sink #1

Collector: Client

Collect Date: 05/11/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:51	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:51	MAW

Sample Number: 9054773-41

Site: AO

Sample ID: 5th Fl, Slop Sink

Collector: Client

Collect Date: 05/14/2019 7:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
<b>Metals</b>										
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:53	MAW
Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	05/30/19	MAW	06/05/19 1:53	MAW

## Data Qualifiers:

T1 Turbidity is >1 and the sample was not digested.

## Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

## Reviewed and Released By:

Lisa F. Care  
Project Manager I

Report Generated On: 06/05/2019 12:46 pm  
STL\_DW\_Results Revision #1.7

9054773  
Effective: 07/09/2014



61

9054773  
Lisa F. CareTAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other \_\_\_\_\_  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Suburban Property Inspections

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

Fax: \_\_\_\_\_

Contact Name: \_\_\_\_\_ Email: \_\_\_\_\_

ie: Philadelphia OICAddress: 1231 N. Broad St., 4th FloorPhiladelphia, PA 19122Payment / P.O. Info: 153237

Comments:

Page 1 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Sampler's Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓ A-2nd, Ladies, Sink 3	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ B-2nd, Ladies, Sink 2	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ C-2nd, Ladies, Sink 1	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ D-2nd, Staff bathroom	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ E-2nd Fl, Men's Room, Sink #2	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ F-2nd, men's, Sink 1	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ G-3rd Fl, Hallway, <sup>Water</sup> Fountain	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				
✓ H-3rd Fl, Ladiesroom, Sink 1	5/4/19 07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P				

Relinquished By:	Date:	
	Time:	
Received By: <u>Melvin Curtis</u>	Date: <u>5/21/19</u>	Temp °C: <u>34.2</u>
	Time: <u>10:30</u>	Acceptable: <u>Y</u> / N
Relinquished By: <u>Malen</u>	Date: <u>5-22-19</u>	Temp °C: <u>11.2</u>
	Time: <u>1450</u>	Acceptable: Y / N
Received in Lab By:	Date:	Temp °C: _____
	Time:	Acceptable: Y / N

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. Shaded areas are for SWTL use only.

**Suburban Testing Labs**Lab Date/Time: 5/21/19 1938 Lab Temp: 3.6Number of containers/coolers match number on COC? Y N  
Sample labels and COC are free of discrepancies? Y N  
All containers in tact? Y N  
Received in lab within acceptable temperature limits? Y N  
40mL VOA vials free of headspace? Y NRelinquished by: MalenReceived in Lab by: IRP 82

Key	Reporting Options
<input type="checkbox"/>	SDWA Reporting
	PWSID: _____
<input type="checkbox"/>	Fax
<input type="checkbox"/>	Email
<input type="checkbox"/>	Other _____
<input type="checkbox"/>	Return a copy of this form with Report



9054773  
Lisa F. Care

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Suburban Property Inspections

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

\_\_\_\_\_ Fax: \_\_\_\_\_

Contact Name: \_\_\_\_\_ Email: \_\_\_\_\_

City: Philadelphia OIC

Address: 1231 N. Broad St., 4th Floor

Philadelphia, PA 19122

Payment / P.O. Info: 153237

Comments:

Page 2 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓ I- 3 <sup>rd</sup> , Ladies, Sink 2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ J- 3 <sup>rd</sup> Fl, Men's Room, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ K- 3 <sup>rd</sup> , Men's, Sink 3	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ L- 5 <sup>th</sup> , Staff bathroom	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ M- 1 <sup>st</sup> Fl Sink	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ N- 3 <sup>rd</sup> , Kitchen sink	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ O- 4 <sup>th</sup> , water fountain lunch room	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			
✓ P- 5 <sup>th</sup> , Small Men's, Sink 1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P			

Relinquished By:	Date:		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date: 5/22/19	Temp °C: 11.2	Submitted with COC? Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
Relinquished By:	Date: 5/22/19	Temp °C: 3.5	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received in Lab By:	Date: 5/22/19	Temp °C: _____	All containers in tact? Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
	Date: 5/22/19	Temp °C: _____	Tests within holding times Y / N	SDWA = Safe Drinking Water Act Potable Sample		<input type="checkbox"/> Email
	Date: 5/22/19	Temp °C: _____	40 mL VOA vials free of headspace? Y / N	<b>Sample Type Key</b>	<b>SDWA Sample Types</b>	<input type="checkbox"/> Other _____
	Date: 5/22/19	Temp °C: _____		G = Grab	D = Distribution	<input type="checkbox"/> Return a copy of this form with Report
	Date: 5/22/19	Temp °C: _____		8HC = 8 Hr. Composite	E = Entry Point	
	Date: 5/22/19	Temp °C: _____		24HC = 24 Hr. Composite	R = Raw	
	Date: 5/22/19	Temp °C: _____			C = Check	
	Date: 5/22/19	Temp °C: _____			S = Special	
	Date: 5/22/19	Temp °C: _____			M = Maximum Residence	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.



**SUBURBAN**  
TESTING LABS

61



9054773  
Lisa F. Care

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID:

Client Name: Suburban Property Inspections

Address: Phone:

Fax:

Contact Name: Email:

Philadelphia OIC

Address: 1231 N. Broad St., 4th Floor

Philadelphia, PA 19122

Payment / P.O. Info: 153237

Comments:

Page 3 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓	Q- 4th Fl, Men's, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	R- 5th, Small Men's, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	S- 5th Fl, Ladies Room, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	T- 4th Fl, Lounge, Sink	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	U- 5th, Large Men's, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	V- 5th Fl, Water Fountain	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	W- 5th, Starbucks, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	X- 5th Fl, Starbucks, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		

Relinquished By:	Date:		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
	Time:		Submitted with COC? Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
Received By:	Date: 5/22/19	Temp °C: 16.2	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
	Time: 1450	Acceptable: Y / N	All containers in tact? Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
Relinquished By:	Date: 5/22/19	Temp °C: 3.5	Tests within holding times Y / N	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> Email
	Time: 1930	Acceptable: Y / N	40 mL VOA vials free of headspace? Y / N	Sample Type Key	N = Sodium Thiosulfate	<input type="checkbox"/> Other _____
Received in Lab By:	Date:	Temp °C: _____		SDWA Sample Types	A = Ascorbic Acid	<input type="checkbox"/> Return a copy of this form with Report
	Time:	Acceptable: Y / N		G = Grab	H = HNO <sub>3</sub>	
				8HC = 8 Hr. Composite	C = HCl	
				24HC = 24 Hr. Composite	R = Raw	
					C = Check	
					S = Special	
					M = Maximum Residence	
					OH = NaOH	
					O = Other	
					NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.



610-

9054773  
Lisa F. CareTAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Suburban Property Inspections

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

Fax: \_\_\_\_\_

Contact Name: \_\_\_\_\_ Email: \_\_\_\_\_

Address: Philadelphia OIC  
1231 N. Broad St., 4th Floor  
Philadelphia, PA 19122  
Payment / P.O. Info: 153237

Comments:

Page 4 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓	Y-5th Fl, Ladies Room, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	Z-5th, Large Men's, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AA-4th Fl, Mens, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AB-4th Fl, Ladies Room, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AC-4th Fl, HTI, Ladies, Sink #2	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AD-4th Fl, Ladies Room, Sink #1	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AE-4th Fl, HTI, Water Fountain	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AF-3rd Fl, Mens, Sink #2	5/4/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		

Relinquished By:	Date:		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
	Time:		Submitted with COC? Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
Received By:	Date: 5/22/19	Temp °C: 41.2	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
	Time: 1450	Acceptable: Y / N	All containers in tact? Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
Relinquished By:	Date: 5/22/19	Temp °C: 35	Tests within holding times Y / N	SDWA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>	<input type="checkbox"/> Email
	Time: 1932	Acceptable: Y / N	40 mL VOA vials free of headspace? Y / N	<b>Sample Type Key</b>	N = Sodium Thiosulfate	<input type="checkbox"/> Other
Received in Lab By:	Date:	Temp °C: _____		<b>SDWA Sample Types</b>	A = Ascorbic Acid	<input type="checkbox"/> Return a copy of this form with Report
	Time:	Acceptable: Y / N		G = Grab	H = HNO <sub>3</sub>	
				8HC = 8 Hr. Composite	C = HCl	
				24HC = 24 Hr. Composite	S = H <sub>2</sub> SO <sub>4</sub>	
					OH = NaOH	
					O = Other	
					NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.



61

9054773  
Lisa F. CareTAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Suburban Property Inspections

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

Fax: \_\_\_\_\_

Email: \_\_\_\_\_

Contact Name: \_\_\_\_\_

Address: Philadelphia OIC  
1231 N. Broad St., 4th Floor  
Philadelphia, PA 19122  
Payment / P.O. Info: 153237

Comments:

Page 5 of 6

Comments:

Page 5 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓	AG-4th, Ladies, Sink 3	5/14/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AH-4th Fl, Men's Room, HTI, Sink #1	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AI-4th Fl, Men's Room, Sink #3	5/14/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AJ-2nd Fl, Water Fountain	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AK-4th Fl, HTI, men's Room, Sink #2	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AL-4th, HTI, Ladies Room, Sink #3	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AM-3rd Fl, Slope Sink	5/14/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		
✓	AN-4th Fl, HTI, Ladies, Sink #1	5/11/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		

Reporting Options

Matrix Key

Bottle Type Key

Reporting Options


Relinquished By: _____	Date: _____	Temp °C: _____	Acceptable: Y / N	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: _____	Date: 5/22/19	Temp °C: 16.2	Acceptable: Y / N	Submitted with COC? Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
Relinquished By: _____	Date: 5/28/19	Temp °C: 3.5	Acceptable: Y / N	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received In Lab By: _____	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N	All containers in tact? Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N	Tests within holding times Y / N	SDWA = Safe Drinking Water Act, Potable Sample		<input type="checkbox"/> Email
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N	40 mL VOA vials free of headspace? Y / N	Sample Type Key	Preservative Key	<input type="checkbox"/> Other _____
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N		G = Grab	N = Sodium Thiosulfate	<input type="checkbox"/> Return a copy of this form with Report
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N		8HC = 8 Hr. Composite	A = Ascorbic Acid	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N		24HC = 24 Hr. Composite	H = HNO <sub>3</sub>	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N			C = HCl	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N			S = H <sub>2</sub> SO <sub>4</sub>	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N			OH = NaOH	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N			O = Other	
	Date: 5/28/19	Temp °C: _____	Acceptable: Y / N			NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.



# SUBURBAN TESTING LABS

6

9054773  
Lisa F. CareTAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Suburban Property Inspections

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

Fax: \_\_\_\_\_

Email: \_\_\_\_\_

Contact Name: \_\_\_\_\_

me: Philadelphia OICAddress: 1231 N. Broad St., 4th FloorPhiladelphia, PA 19122Payment / P.O. Info: 153237

Comments:

Page 6 of 6

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
✓	AO- 5th Fl, Slop Sink	5/14/19	07:00	Client	Lead, 200.8, Standing & Flushed	2	PW	G	P		

Relinquished By:	Date:		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date: 5/20/19	Temp °C: 46.2	Submitted with COC? Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
Relinquished By:	Time: 1:45 PM	Acceptable: Y / N	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received In Lab By:	Date: 5/20/19	Temp °C: 35	All containers in tact? Y / N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
	Time: 1:52 PM	Acceptable: Y / N	Tests within holding times Y / N	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> Email
	Date:	Temp °C: _____	40 mL VOA vials free of headspace? Y / N	Sample Type Key	N = Sodium	<input type="checkbox"/> Other
	Time:	Acceptable: Y / N		SDWA Sample Types	A = Ascorbic Acid	<input type="checkbox"/> Return a copy of this form with Report
				G = Grab	H = HNO <sub>3</sub>	
				8HC = 8 Hr. Composite	C = Check	
				24HC = 24 Hr. Composite	S = Special	
					M = Maximum Residence	
					NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014  
Shaded areas are for SWTL use only.