



Drinking Water Results Report

Order ID: 9123096

Suburban Property Inspections 4600 Kutztown Road Temple, PA 19560	Project: Philadelphia OIC 1231 N. Broad Street, 4th Floor Philadelphia, PA 19122
Attn: Jonathan D. Stump	PWSID:

Sample Number: 9123096-01	Site: 3rd Floor, Mens Sink 1	Sample ID: 154280
Collector: Client	Collect Date: 12/09/2019 6:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead, Standing	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/17/19	RPV	12/17/19 23:05	MAW
----------------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.


Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 12/18/2019 2:39 pm 9123096
STL_DW_Results Revision #1.7 Effective: 07/09/2014




 9123096
 Lisa F. Care

 Client Name: Suburban Property Inspections

Address: _____

Contact Name: _____

Fax: _____

Email: _____

Philadelphia OIC

231 N. Broad Street, 4th Floor

Philadelphia, PA 19122

 Payment / P.O. Info: 154280

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	3rd Floor, Mens sink 1 250mlp	12/9	06:00	Client	Standing Lead, 200.8	1	PW	G	P		

Suburban Testing Labs

 Lab Date/Time: 12-13-19 14:52 Lab Temp: 5.7

 Number of containers/coolers match number on COC? Y / N
 Sample labels and COC are free of discrepancies? Y / N
 All containers in tact? Y / N
 Received in lab within acceptable temperature limits? Y / N
 40mL VOA vials free of headspace? Y / N

 Relinquished by: TVL

 Received in Lab by: EWI

Relinquished By:	Date:	Temp °C:
	Time:	
Received By:	Date:	Temp °C:
<u>Melissa Guitto</u>	<u>12/13/19</u>	<u>23.1</u>
	Time:	Acceptable: Y / N
	<u>10:00</u>	<input checked="" type="checkbox"/> Y / <input type="checkbox"/> N
Relinquished By:	Date:	Temp °C:
<u>Rec'd TVL</u>	<u>12-13-19</u>	<u>6.1</u>
	Time:	Acceptable: Y / N
	<u>14:24</u>	<input type="checkbox"/> Y / <input type="checkbox"/> N
Received in Lab By:	Date:	Temp °C:
	Time:	Acceptable: Y / N

Reporting Options	
<input type="checkbox"/>	SDWA Reporting
PWSID: _____	
<input type="checkbox"/>	Fax
<input type="checkbox"/>	Email
<input type="checkbox"/>	Other _____
<input type="checkbox"/>	Return a copy of this form with Report